



NEGROS PRAWN PRODUCERS COOPERATIVE ANALYTICAL & DIAGNOSTIC LABORATORY

Door No.1 & 2, NOLKFI Bldg., 6th Street, Brgy. 7, Bacolod City
Tele/Fax 034-4332131 email address nppclab@gmail.com



WATER BACTERIOLOGY ANALYSIS TEST REPORT

Customer: Bayawan Water District
Address: Napit-an, Bayawan City, Neg. Or.
Ref. No.: 24-70963
Sample Collected by: Anthony Hermosa
Water Supply: Local Water District
Sampling Point: Faucet

Date/Time of Collection: 01/31/24 (11:35am)
Receipt : 02/01/24 (11:00am)
Examination : 02/01/24 (11:30am)
Report : 02/05/24
Release : 02/05/24
Sample Description: Water in sterile bottle

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sample Code	Control No.	Results of Analysis		
		Total Coliform (MPN/100 ml)	Thermotolerant Coliforms (MPN/100 ml)	HPC (CFU/ml)
Elsa Pamilaga	24-01281N	< 1.1	< 1.1	< 10
Interpretation		Pass	Pass	Pass
Acceptable Values: PNSDW 2017 AO 2017-0010		< 1.1	< 1.1	< 500

Test method used (TC & FC): Multiple Tube Fermentation Technique, SMEWW 23rd Edition, 2017

Test method used (HPC): Spread Plate Method. 9215 C, SMEWW 23rd Edition, 2017

Room Temperature and %Relative Humidity during analysis: 23°C, 50%

NOTE:

1. This report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results contained in this report relate only to the items received, coded and tested by the laboratory.
3. Measurement uncertainty is available upon request.
4. Statements of conformity (e.g. Pass/Fail) to specifications are made in this report without taking measurement uncertainty into account except when requested by the customer. Where statements of conformity are made in this report, the following decision rules are applied: PASS - Results within limits; FAIL - Results exceed limits

Analyzed by:

WENDY A. TAYSON
Approved Signatory (Micro)

Noted by:

JASON JAMES P. LUSABIA, RMT
PRC License No. 72018

Approved for Release:

ROSELYN C. USERO, RCh, MEE
Manager/Laboratory Head
Approved Signatory (Micro)

Test Report #: MICDW-69064
Laboratory DOH Accreditation # 01
NPPC-ADL LSP 7.8 F05
Rev. 3/Issue 4
Effectivity Date: 06/15/22



**NEGROS PRAWN PRODUCERS COOPERATIVE
ANALYTICAL & DIAGNOSTIC LABORATORY**

Door No.1 & 2, NOLKFI Bldg., 6th Street., Brgy. 7, Bacolod City
Tele/Fax 034-4332131 email address nppclab@gmail.com



WATER BACTERIOLOGY ANALYSIS TEST REPORT

Customer: Bayawan Water District	Date/Time of Collection: 01/31/24 (10:50am)
Address: GV Sub./Villareal, Bayawan City, Neg. Or.	Receipt : 02/01/24 (11:00am)
Ref. No.: 24-70963	Examination : 02/01/24 (11:30am)
Sample Collected by: Anthony Hermosa	Report : 02/05/24
Water Supply: Local Water District	Release : 02/05/24
Sampling Point: Faucet	Sample Description: Water in sterile bottle

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sample Code	Control No.	Results of Analysis		
		Total Coliform (MPN/100 ml)	Thermotolerant Coliforms (MPN/100 ml)	HPC (CFU/ml)
Arlene Gutib	24-012810	< 1.1	< 1.1	< 10
Interpretation		Pass	Pass	Pass
Acceptable Values: PNSDW 2017 AO 2017-0010		< 1.1	< 1.1	< 500

Test method used (TC & FC): Multiple Tube Fermentation Technique, SMEWW 23rd Edition, 2017

Test method used (HPC): Spread Plate Method. 9215 C, SMEWW 23rd Edition, 2017

Room Temperature and %Relative Humidity during analysis: 23°C, 50%

NOTE:

1. This report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results contained in this report relate only to the items received, coded and tested by the laboratory.
3. Measurement uncertainty is available upon request.
4. Statements of conformity (e.g. Pass/Fail) to specifications are made in this report without taking measurement uncertainty into account except when requested by the customer. Where statements of conformity are made in this report, the following decision rules are applied : PASS - Results within limits; FAIL - Results exceed limits

Analyzed by:

WENDY K. TAYSON
Approved Signatory (Micro)

Noted by:

JASON JAMES P. LUSABIA, RMT
PRC License No. 72018

Approved for Release

ROSELYN C. USERO, RCh, MEE
Manager/Laboratory Head
Approved Signatory (Micro)

Test Report #: MICDW-69065
Laboratory DOH Accreditation # 01
NPPC-ADL LSP 7.8 FO5
Rev. 3/Issue 4
Effectivity Date: 06/15/22



**NEGROS PRAWN PRODUCERS COOPERATIVE
ANALYTICAL & DIAGNOSTIC LABORATORY**

Door No.1 & 2, NOLKFI Bldg., 6th Street., Brgy. 7, Bacolod City
Tele/Fax 034-4332131 email address nppclub@gmail.com



WATER BACTERIOLOGY ANALYSIS TEST REPORT

Customer: Bayawan Water District
Address: Amparos, Bayawan City, Neg. Or.
Ref. No.: 24-70963
Sample Collected by: Anthony Hermosa
Water Supply: Local Water District
Sampling Point: Faucet

Date/Time of Collection: 01/31/24 (11:50am)
Receipt : 02/01/24 (11:00am)
Examination : 02/01/24 (11:30am)
Report : 02/05/24
Release : 02/05/24
Sample Description: Water in sterile bottle

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sample Code	Control No.	Results of Analysis		
		Total Coliform (MPN/100 ml)	Thermotolerant Coliforms (MPN/100 ml)	HPC (CFU/ml)
Magdalino Café	24-012811	< 1.1	< 1.1	< 10
Interpretation		Pass	Pass	Pass
Acceptable Values: PNSDW 2017 AO 2017-0010		< 1.1	< 1.1	< 500

Test method used (TC & FC): Multiple Tube Fermentation Technique, SMEWW 23rd Edition, 2017
Test method used (HPC): Spread Plate Method. 9215 C, SMEWW 23rd Edition, 2017
Room Temperature and %Relative Humidity during analysis: 23°C, 50%

NOTE:

1. This report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results contained in this report relate only to the items received, coded and tested by the laboratory.
3. Measurement uncertainty is available upon request.
4. Statements of conformity (e.g. Pass/Fail) to specifications are made in this report without taking measurement uncertainty into account except when requested by the customer. Where statements of conformity are made in this report, the following decision rules are applied: PASS - Results within limits; FAIL - Results exceed limits

Analyzed by:

WENDY A. TAYSON
Approved Signatory (Micro)

Noted by:

JASON JAMES P. LUSABIA, RMT
PRC License No. 72018

Approved for Release:

ROSELYN C. USERO, RCh, MEE
Manager/Laboratory Head
Approved Signatory (Micro)

Test Report #: MICDW-69059
Laboratory DOH Accreditation # 01
NPPC-ADL LSP 7.8 F05
Rev. 3/Issue 4
Effectivity Date: 06/15/22



NEGROS PRAWN PRODUCERS COOPERATIVE ANALYTICAL & DIAGNOSTIC LABORATORY

Door No.1 & 2, NOLKFI Bldg., 6th Street., Brgy. 7, Bacolod City
Tele/Fax 034-4332131 email address nppclab@gmail.com



WATER BACTERIOLOGY ANALYSIS TEST REPORT

Customer: Bayawan Water District
Address: Brgy. Malabugas, Bayawan City, Neg. Or.
Ref. No.: 24-70963
Sample Collected by: Anthony Hermosa
Water Supply: Local Water District
Sampling Point: Faucet

Date/Time of Collection: 01/31/24 (8:25am)
Receipt : 02/01/24 (11:00am)
Examination : 02/01/24 (11:20am)
Report : 02/05/24
Release : 02/05/24
Sample Description: Water in sterile bottle

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sample Code	Control No.	Results of Analysis		
		Total Coliform (MPN/100 ml)	Thermotolerant Coliforms (MPN/100 ml)	HPC (CFU/ml)
Glendel Tumale	24-01281A	< 1.1	< 1.1	< 10
Interpretation		Pass	Pass	Pass
Acceptable Values: PNSDW 2017 AO 2017-0010		< 1.1	< 1.1	< 500

Test method used (TC & FC): Multiple Tube Fermentation Technique, SMEWW 23rd Edition, 2017

Test method used (HPC): Spread Plate Method. 9215 C, SMEWW 23rd Edition, 2017

Room Temperature and %Relative Humidity during analysis: 23°C, 50%

NOTE:

1. This report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results contained in this report relate only to the items received, coded and tested by the laboratory.
3. Measurement uncertainty is available upon request.
4. Statements of conformity (e.g. Pass/Fail) to specifications are made in this report without taking measurement uncertainty into account except when requested by the customer. Where statements of conformity are made in this report, the following decision rules are applied: PASS - Results within limits; FAIL - Results exceed limits

Analyzed by:

WENDY A. TAYSON
Approved Signatory (Micro)

Noted by:

JASON JAMES P. LUSABIA, RMT
PRC License No. 72018

Approved for Release:

ROSELYN C. USERO, RCh, MEE
Manager/Laboratory Head
Approved Signatory (Micro)

Test Report #: MICDW-69051
Laboratory DOH Accreditation # 01
NPPC-ADL LSP 7.8 FO5
Rev. 3/Issuc 4
Effectivity Date: 06/15/22



NEGROS PRAWN PRODUCERS COOPERATIVE ANALYTICAL & DIAGNOSTIC LABORATORY

Door No.1 & 2, NOLKFI Bldg., 6th Street., Brgy. 7, Bacolod City
Tele/Fax 034-4332131 email address nppclab@gmail.com



WATER BACTERIOLOGY ANALYSIS TEST REPORT

Customer: Bayawan Water District
Address: Brgy. Banga, Bayawan City, Neg. Or.
Ref. No.: 24-70963
Sample Collected by: Anthony Hermosa
Water Supply: Local Water District
Sampling Point: Faucet

Date/Time of Collection: 01/31/24 (8:37am)
Receipt : 02/01/24 (11:00am)
Examination : 02/01/24 (11:20am)
Report : 02/05/24
Release : 02/05/24
Sample Description: Water in sterile bottle

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sample Code	Control No.	Results of Analysis		
		Total Coliform (MPN/100 ml)	Thermotolerant Coliforms (MPN/100 ml)	HPC (CFU/ml)
Avelino Loquenario	24-01281B	< 1.1	< 1.1	< 10
Interpretation		Pass	Pass	Pass
Acceptable Values: PNSDW 2017 AO 2017-0010		< 1.1	< 1.1	< 500

Test method used (TC & FC): Multiple Tube Fermentation Technique, SMEWW 23rd Edition, 2017

Test method used (HPC): Spread Plate Method. 9215 C, SMEWW 23rd Edition, 2017

Room Temperature and %Relative Humidity during analysis: 23°C, 50%

NOTE:

1. This report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results contained in this report relate only to the items received, coded and tested by the laboratory.
3. Measurement uncertainty is available upon request.
4. Statements of conformity (e.g. Pass/Fail) to specifications are made in this report without taking measurement uncertainty into account except when requested by the customer. Where statements of conformity are made in this report, the following decision rules are applied : PASS - Results within limits; FAIL - Results exceed limits

Analyzed by:

WENDY A. TAYSON
Approved Signatory (Micro)

Noted by:

JASON JAMES P. LUSABIA, RMT
PRC License No. 72018

Approved for Release:

ROSELYN C. USERO, RCh, MEE
Manager/Laboratory Head
Approved Signatory (Micro)

Test Report #: MICDW-69052
Laboratory DOH Accreditation # 01
NPPC-ADL LSP 7.8 FO5
Rev. 3/Issue 4
Effectivity Date: 06/15/22



NEGROS PRAWN PRODUCERS COOPERATIVE ANALYTICAL & DIAGNOSTIC LABORATORY

Door No.1 & 2, NOLKFI Bldg., 6th Street., Brgy. 7, Bacolod City
Tele/Fax 034-4332131 email address nppclab@gmail.com



WATER BACTERIOLOGY ANALYSIS TEST REPORT

Customer: Bayawan Water District	Date/Time of Collection: 01/31/24 (8:53am)
Address: Lopezville/Banga, Bayawan City, Neg. Or.	Receipt : 02/01/24 (11:00am)
Ref. No.: 24-70963	Examination : 02/01/24 (11:20am)
Sample Collected by: Anthony Hermosa	Report : 02/05/24
Water Supply: Local Water District	Release : 02/05/24
Sampling Point: Faucet	Sample Description: Water in sterile bottle

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sample Code	Control No.	Results of Analysis		
		Total Coliform (MPN/100 ml)	Thermotolerant Coliforms (MPN/100 ml)	HPC (CFU/ml)
Nuique Serio	24-01281C	< 1.1	< 1.1	< 10
Interpretation		Pass	Pass	Pass
Acceptable Values: PNSDW 2017 AO 2017-0010		< 1.1	< 1.1	< 500

Test method used (TC & FC): Multiple Tube Fermentation Technique, SMEWW 23rd Edition, 2017

Test method used (HPC): Spread Plate Method. 9215 C, SMEWW 23rd Edition, 2017

Room Temperature and %Relative Humidity during analysis: 23°C, 50%

NOTE:

1. This report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results contained in this report relate only to the items received, coded and tested by the laboratory.
3. Measurement uncertainty is available upon request.
4. Statements of conformity (e.g. Pass/Fail) to specifications are made in this report without taking measurement uncertainty into account except when requested by the customer. Where statements of conformity are made in this report, the following decision rules are applied : PASS - Results within limits; FAIL - Results exceed limits

Analyzed by:

WENDY A. JAYSON
Approved Signatory (Micro)

Noted by:

JASON JAMES P. LUSABIA, RMT
PRO License No. 72018

Approved for Release:

ROSELYN C. USERO, RCh, MEE
Manager/Laboratory Head
Approved Signatory (Micro)

Test Report #: MICDW-69053
Laboratory DOH Accreditation # 01
NPPC-ADL LSP 7.8 FO5
Rev. 3/Issue 4
Effectivity Date: 06/15/22



NEGROS PRAWN PRODUCERS COOPERATIVE ANALYTICAL & DIAGNOSTIC LABORATORY

Door No.1 & 2, NOLKFI Bldg., 6th Street., Brgy. 7, Bacolod City
Tele/Fax 034-4332131 email address nppclab@gmail.com



WATER BACTERIOLOGY ANALYSIS TEST REPORT

Customer: Bayawan Water District
Address: Brgy. Ubos, Bayawan City, Neg. Or.
Ref. No.: 24-70963
Sample Collected by: Anthony Hermosa
Water Supply: Local Water District
Sampling Point: Faucet

Date/Time of Collection: 01/31/24 (9:10am)
Receipt : 02/01/24 (11:00am)
Examination : 02/01/24 (11:20am)
Report : 02/05/24
Release : 02/05/24
Sample Description: Water in sterile bottle

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sample Code	Control No.	Results of Analysis		
		Total Coliform (MPN/100 ml)	Thermotolerant Coliforms (MPN/100 ml)	HPC (CFU/ml)
Rose Trumata	24-01281D	< 1.1	< 1.1	< 10
Interpretation		Pass	Pass	Pass
Acceptable Values: PNSDW 2017 AO 2017-0010		< 1.1	< 1.1	< 500

Test method used (TC & FC): Multiple Tube Fermentation Technique, SMEWW 23rd Edition, 2017

Test method used (HPC): Spread Plate Method. 9215 C, SMEWW 23rd Edition, 2017

Room Temperature and %Relative Humidity during analysis: 23°C, 50%

NOTE:

1. This report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results contained in this report relate only to the items received, coded and tested by the laboratory.
3. Measurement uncertainty is available upon request.
4. Statements of conformity (e.g. Pass/Fail) to specifications are made in this report without taking measurement uncertainty into account except when requested by the customer. Where statements of conformity are made in this report, the following decision rules are applied: PASS - Results within limits; FAIL - Results exceed limits

Analyzed by:

WENDY A. TAYSON
Approved Signatory (Micro)

Noted by:

JASON JAMES P. LUSABIA, RMT
PRC License No. 72018

Approved for Release:

ROSELYN C. USERO, RCh, MEE
Manager/Laboratory Head
Approved Signatory (Micro)

Test Report #: MICDW-69054
Laboratory DOH Accreditation # 01
NPPC-ADL LSP 7.8 FO5
Rev. 3/Issue 4
Effectivity Date: 06/15/22



**NEGROS PRAWN PRODUCERS COOPERATIVE
ANALYTICAL & DIAGNOSTIC LABORATORY**

Door No.1 & 2., NOLKFI Bldg., 6th Street., Brgy. 7, Bacolod City
Tele/Fax 034-4332131 email address nppclub@gmail.com



WATER BACTERIOLOGY ANALYSIS TEST REPORT

Customer: Bayawan Water District	Date/Time of Collection: 01/31/24 (9:25am)
Address: Brgy. Poblacion, Bayawan City, Neg. Or.	Receipt : 02/01/24 (11:00am)
Ref. No.: 24-70963	Examination : 02/01/24 (11:20am)
Sample Collected by: Anthony Hermosa	Report : 02/05/24
Water Supply: Local Water District	Release : 02/05/24
Sampling Point: Faucet	Sample Description: Water in sterile bottle

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sample Code	Control No.	Results of Analysis		
		Total Coliform (MPN/100 ml)	Thermotolerant Coliforms (MPN/100 ml)	HPC (CFU/ml)
Emmanuel Borromeo	24-01281E	< 1.1	< 1.1	< 10
Interpretation		Pass	Pass	Pass
Acceptable Values: PNSDW 2017 AO 2017-0010		< 1.1	< 1.1	< 500

Test method used (TC & FC): Multiple Tube Fermentation Technique, SMEWW 23rd Edition, 2017

Test method used (HPC): Spread Plate Method. 9215 C, SMEWW 23rd Edition, 2017

Room Temperature and %Relative Humidity during analysis: 23°C, 50%

NOTE:

1. This report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results contained in this report relate only to the items received, coded and tested by the laboratory.
3. Measurement uncertainty is available upon request.
4. Statements of conformity (e.g. Pass/Fail) to specifications are made in this report without taking measurement uncertainty into account except when requested by the customer. Where statements of conformity are made in this report, the following decision rules are applied : PASS - Results within limits; FAIL - Results exceed limits

Analyzed by:

WENDY X. TAYSON
Approved Signatory (Micro)

Noted by:

JASON JAMES P. LUSABIA, RMT
PRC License No. 72018

Approved for Release:

ROSELYN C. USERO, RCh, MEE
Manager/Laboratory Head
Approved Signatory (Micro)

Test Report #: MICDW-69055
Laboratory DOH Accreditation # 01
NPPC-ADL LSP 7.8 FO5
Rev. 3/Issue 4
Effectivity Date: 06/15/22



NEGROS PRAWN PRODUCERS COOPERATIVE ANALYTICAL & DIAGNOSTIC LABORATORY

Door No. 1 & 2, NOLKFI Bldg., 6th Street., Brgy. 7, Bacolod City
Tele/Fax 034-4332131 email address nppclab@gmail.com



WATER BACTERIOLOGY ANALYSIS TEST REPORT

Customer: Bayawan Water District
Address: Brgy. Suba, Bayawan City, Neg. Or.
Ref. No.: 24-70963
Sample Collected by: Anthony Hermosa
Water Supply: Local Water District
Sampling Point: Faucet

Date/Time of Collection: 01/31/24 (9:36am)
Receipt : 02/01/24 (11:00am)
Examination : 02/01/24 (11:20am)
Report : 02/05/24
Release : 02/05/24
Sample Description: Water in sterile bottle

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sample Code	Control No.	Results of Analysis		
		Total Coliform (MPN/100 ml)	Thermotolerant Coliforms (MPN/100 ml)	HPC (CFU/ml)
Brgy. Health Center	24-01281F	< 1.1	< 1.1	< 10
Interpretation		Pass	Pass	Pass
Acceptable Values: PNSDW 2017 AO 2017-0010		< 1.1	< 1.1	< 500

Test method used (TC & FC): Multiple Tube Fermentation Technique, SMEWW 23rd Edition, 2017

Test method used (HPC): Spread Plate Method. 9215 C, SMEWW 23rd Edition, 2017

Room Temperature and %Relative Humidity during analysis: 23°C, 50%

NOTE:

1. This report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results contained in this report relate only to the items received, coded and tested by the laboratory.
3. Measurement uncertainty is available upon request.
4. Statements of conformity (e.g. Pass/Fail) to specifications are made in this report without taking measurement uncertainty into account except when requested by the customer. Where statements of conformity are made in this report, the following decision rules are applied : PASS - Results within limits; FAIL - Results exceed limits

Analyzed by:

WENDY A. TAYSON
Approved Signatory (Micro)

Noted by:

JASON JAMES P. LUSABIA, RMT
PRC License No. 72018

Approved for Release:

ROSELYN C. USERO, RCh, MEE
Manager/Laboratory Head
Approved Signatory (Micro)

Test Report #: MICDW-69056
Laboratory DOH Accreditation # 01
NPPC-ADL LSP 7.8 FO5
Rev. 3/Issue 4
Effectivity Date: 06/15/22



**NEGROS PRAWN PRODUCERS COOPERATIVE
ANALYTICAL & DIAGNOSTIC LABORATORY**

Door No.1 & 2, NOLKFI Bldg., 6th Street., Brgy. 7, Bacolod City
Tele/Fax 034-4332131 email address nppclub@gmail.com



WATER BACTERIOLOGY ANALYSIS TEST REPORT

Customer: Bayawan Water District	Date/Time of Collection: 01/31/24 (9:40am)
Address: Brgy. Boyco, Bayawan City, Neg. Or.	Receipt : 02/01/24 (11:00am)
Ref. No.: 24-70963	Examination : 02/01/24 (11:20am)
Sample Collected by: Anthony Hermosa	Report : 02/05/24
Water Supply: Local Water District	Release : 02/05/24
Sampling Point: Faucet	Sample Description: Water in sterile bottle

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sample Code	Control No.	Results of Analysis		
		Total Coliform (MPN/100 ml)	Thermotolerant Coliforms (MPN/100 ml)	HPC (CFU/ml)
Emmanuel Torreda	24-01281G	< 1.1	< 1.1	< 10
Interpretation		Pass	Pass	Pass
Acceptable Values: PNSDW 2017 AO 2017-0010		< 1.1	< 1.1	< 500

Test method used (TC & FC): Multiple Tube Fermentation Technique, SMEWW 23rd Edition, 2017

Test method used (HPC): Spread Plate Method. 9215 C, SMEWW 23rd Edition, 2017

Room Temperature and %Relative Humidity during analysis: 23°C, 50%

NOTE:

1. This report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results contained in this report relate only to the items received, coded and tested by the laboratory.
3. Measurement uncertainty is available upon request.
4. Statements of conformity (e.g. Pass/Fail) to specifications are made in this report without taking measurement uncertainty into account except when requested by the customer. Where statements of conformity are made in this report, the following decision rules are applied : PASS - Results within limits; FAIL - Results exceed limits

Analyzed by:

WENDY A. TAYSON
Approved Signatory (Micro)

Noted by:

JASON JAMES P. LUSABIA, RMT
PIC License No. 72018

Approved for Release:

ROSELYN C. USERO, RCh, MEE
Manager/Laboratory Head
Approved Signatory (Micro)

Test Report #: MICDW-69057
Laboratory DOH Accreditation # 01
NPPC-ADL LSP 7.8 F05
Rev. 3/Issue 4
Effectivity Date: 06/15/22



NEGROS PRAWN PRODUCERS COOPERATIVE ANALYTICAL & DIAGNOSTIC LABORATORY

Door No.1 & 2, NOLKFI Bldg., 6th Street., Brgy. 7, Bacolod City
Tele/Fax 034-4332131 email address nppclab@gmail.com



WATER BACTERIOLOGY ANALYSIS TEST REPORT

Customer: Bayawan Water District
Address: Brgy. Tinago, Bayawan City, Neg. Or.
Ref. No.: 24-70963
Sample Collected by: Anthony Hermosa
Water Supply: Local Water District
Sampling Point: Faucet

Date/Time of Collection: 01/31/24 (10:05am)
Receipt : 02/01/24 (11:00am)
Examination : 02/01/24 (11:30am)
Report : 02/05/24
Release : 02/05/24
Sample Description: Water in sterile bottle

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sample Code	Control No.	Results of Analysis		
		Total Coliform (MPN/100 ml)	Thermotolerant Coliforms (MPN/100 ml)	HPC (CFU/ml)
Marilou Dizon	24-01281H	< 1.1	< 1.1	< 10
Interpretation		Pass	Pass	Pass
Acceptable Values: PNSDW 2017 AO 2017-0010		< 1.1	< 1.1	< 500

Test method used (TC & FC): Multiple Tube Fermentation Technique, SMEWW 23rd Edition, 2017

Test method used (HPC): Spread Plate Method. 9215 C, SMEWW 23rd Edition, 2017

Room Temperature and %Relative Humidity during analysis: 23°C, 50%

NOTE:

1. This report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results contained in this report relate only to the items received, coded and tested by the laboratory.
3. Measurement uncertainty is available upon request.
4. Statements of conformity (e.g. Pass/Fail) to specifications are made in this report without taking measurement uncertainty into account except when requested by the customer. Where statements of conformity are made in this report, the following decision rules are applied : PASS - Results within limits; FAIL - Results exceed limits

Analyzed by:

WENDY A. TAYSON
Approved Signatory (Micro)

Noted by:

JASON JAMES P. LUSABIA, RMT
PR License No. 72018

Approved for Release:

ROSELYN C. USERO, RCh, MEE
Manager/Laboratory Head
Approved Signatory (Micro)

Test Report #: MICDW-69058
Laboratory DOH Accreditation # 01
NPPC-ADL LSP 7.8 F05
Rev. 3/Issue 4
Effectivity Date: 06/15/22



**NEGROS PRAWN PRODUCERS COOPERATIVE
ANALYTICAL & DIAGNOSTIC LABORATORY**

Door No.1 & 2, NOLKFI Bldg., 6th Street, Brgy. 7, Bacolod City
Tele/Fax 034-4332131 email address nppclab@gmail.com



WATER BACTERIOLOGY ANALYSIS TEST REPORT

Customer: Bayawan Water District
Address: GK Village, Bayawan City, Neg. Or.
Ref. No.: 24-70963
Sample Collected by: Anthony Hermosa
Water Supply: Local Water District
Sampling Point: Faucet

Date/Time of Collection: 01/31/24 (11:00am)
Receipt : 02/01/24 (11:00am)
Examination : 02/01/24 (11:30am)
Report : 02/05/24
Release : 02/05/24
Sample Description: Water in sterile bottle

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sample Code	Control No.	Results of Analysis		
		Total Coliform (MPN/100 ml)	Thermotolerant Coliforms (MPN/100 ml)	HPC (CFU/ml)
Geneveve Cuizon	24-01281J	< 1.1	< 1.1	< 10
Interpretation		Pass	Pass	Pass
Acceptable Values: PNSDW 2017 AO 2017-0010		< 1.1	< 1.1	< 500

Test method used (TC & FC): Multiple Tube Fermentation Technique, SMEWW 23rd Edition, 2017

Test method used (HPC): Spread Plate Method. 9215 C, SMEWW 23rd Edition, 2017

Room Temperature and %Relative Humidity during analysis: 23°C, 50%

NOTE:

1. This report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results contained in this report relate only to the items received, coded and tested by the laboratory.
3. Measurement uncertainty is available upon request.
4. Statements of conformity (e.g. Pass/Fail) to specifications are made in this report without taking measurement uncertainty into account except when requested by the customer. Where statements of conformity are made in this report, the following decision rules are applied : PASS - Results within limits; FAIL - Results exceed limits

Analyzed by:

WENDY A. TAYSON
Approved Signatory (Micro)

Approved for Release

ROSELYN C. USERO, RCh, MEE
Manager/Laboratory Head
Approved Signatory (Micro)

Noted by:

JASON JAMES P. LUSABIA, RMT
PRC License No. 72018

Test Report #: MICDW-69060
Laboratory DOH Accreditation # 01
NPPC-ADL LSP 7.8 FO5
Rev. 3/Issue 4
Effectivity Date: 06/15/22



NEGROS PRAWN PRODUCERS COOPERATIVE ANALYTICAL & DIAGNOSTIC LABORATORY

Door No.1 & 2, NOLKFI Bldg., 5th Street., Brgy. 7, Bacolod City
Tele/Fax 034-4332131 email address nppclab@gmail.com



WATER BACTERIOLOGY ANALYSIS TEST REPORT

Customer: Bayawan Water District	Date/Time of Collection: 01/31/24 (12:10pm)
Address: San Ramon/Pob., Bayawan City, Neg. Or.	Receipt : 02/01/24 (11:00am)
Ref. No.: 24-70963	Examination : 02/01/24 (11:30am)
Sample Collected by: Anthony Hermosa	Report : 02/05/24
Water Supply: Local Water District	Release : 02/05/24
Sampling Point: Faucet	Sample Description: Water in sterile bottle

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sample Code	Control No.	Results of Analysis		
		Total Coliform (MPN/100 ml)	Thermotolerant Coliforms (MPN/100 ml)	HPC (CFU/ml)
Ma. Elvira Baro	24-01281K	< 1.1	< 1.1	< 10
Interpretation		Pass	Pass	Pass
Acceptable Values: PNSDW 2017 AO 2017-0010		< 1.1	< 1.1	< 500

Test method used (TC & FC): Multiple Tube Fermentation Technique, SMEWW 23rd Edition, 2017

Test method used (HPC): Spread Plate Method. 9215 C, SMEWW 23rd Edition, 2017

Room Temperature and %Relative Humidity during analysis: 23°C, 50%

NOTE:

1. This report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results contained in this report relate only to the items received, coded and tested by the laboratory.
3. Measurement uncertainty is available upon request.
4. Statements of conformity (e.g. Pass/Fail) to specifications are made in this report without taking measurement uncertainty into account except when requested by the customer. Where statements of conformity are made in this report, the following decision rules are applied : PASS - Results within limits; FAIL - Results exceed limits

Analyzed by:

WENDY A. JAYSON
Approved Signatory (Micro)

Approved for Release:

ROSELYN C. USERO, RCh, MEE
Manager/Laboratory Head
Approved Signatory (Micro)

Noted by:

JASON JAMES P. LUSABIA, RMT
PIC License No. 72018

Test Report #: MICDW-69061
Laboratory DOH Accreditation # 01
NPPC-ADL LSP 7.8 FO5
Rev. 3/Issue 4
Effectivity Date: 06/15/22



**NEGROS PRAWN PRODUCERS COOPERATIVE
ANALYTICAL & DIAGNOSTIC LABORATORY**

Door No.1 & 2, NOLKFI Bldg., 6th Street., Brgy. 7, Bacolod City
Tele/Fax 034-4332131 email address nppclab@gmail.com



WATER BACTERIOLOGY ANALYSIS TEST REPORT

Customer: Bayawan Water District	Date/Time of Collection: 01/31/24 (11:15am)
Address: Brgy. Caranoche, Bayawan City, Neg. Or.	Receipt : 02/01/24 (11:00am)
Ref. No.: 24-70963	Examination : 02/01/24 (11:30am)
Sample Collected by: Anthony Hermosa	Report : 02/05/24
Water Supply: Local Water District	Release : 02/05/24
Sampling Point: Faucet	Sample Description: Water in sterile bottle

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sample Code	Control No.	Results of Analysis		
		Total Coliform (MPN/100 ml)	Thermotolerant Coliforms (MPN/100 ml)	HPC (CFU/ml)
Dionesio Egay	24-01281L	< 1.1	< 1.1	< 10
Interpretation		Pass	Pass	Pass
Acceptable Values: PNSDW 2017 AO 2017-0010		< 1.1	< 1.1	< 500

Test method used (TC & FC): Multiple Tube Fermentation Technique, SMEWW 23rd Edition, 2017

Test method used (HPC): Spread Plate Method. 9215 C, SMEWW 23rd Edition, 2017

Room Temperature and %Relative Humidity during analysis: 23°C, 50%

NOTE:

1. This report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results contained in this report relate only to the items received, coded and tested by the laboratory.
3. Measurement uncertainty is available upon request.
4. Statements of conformity (e.g. Pass/Fail) to specifications are made in this report without taking measurement uncertainty into account except when requested by the customer. Where statements of conformity are made in this report, the following decision rules are applied : PASS - Results within limits; FAIL - Results exceed limits

Analyzed by:

WENDY A. TAYSON
Approved Signatory (Micro)

Noted by:

JASON JAMES P. LUSABIA, RMT
PRC License No. 72018

Approved for Release:

ROSELYN C. USERO, RCh, MEE
Manager/Laboratory Head
Approved Signatory (Micro)

Test Report #: MICDW-69062
Laboratory DOH Accreditation # 01
NPPC-ADL LSP 7.8 FO5
Rev. 3/Issue 4
Effectivity Date: 06/15/22



**NEGROS PRAWN PRODUCERS COOPERATIVE
ANALYTICAL & DIAGNOSTIC LABORATORY**

Door No.1 & 2, NOLKFI Bldg., 6th Street, Brgy. 7, Bacolod City
Tele/Fax 034-4332131 email address nppclab@gmail.com



WATER BACTERIOLOGY ANALYSIS TEST REPORT

Customer: Bayawan Water District
Address: Maninihon, Bayawan City, Neg. Or.
Ref. No.: 24-70963
Sample Collected by: Anthony Hermosa
Water Supply: Local Water District
Sampling Point: Faucet

Date/Time of Collection: 01/31/24 (11:29am)
Receipt : 02/01/24 (11:00am)
Examination : 02/01/24 (11:30am)
Report : 02/05/24
Release : 02/05/24
Sample Description: Water in sterile bottle

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sample Code	Control No.	Results of Analysis		
		Total Coliform (MPN/100 ml)	Thermotolerant Coliforms (MPN/100 ml)	HPC (CFU/ml)
Naheda Emielyn Hermosa	24-01281M	< 1.1	< 1.1	10
Interpretation		Pass	Pass	Pass
Acceptable Values: PNSDW 2017 AO 2017-0010		< 1.1	< 1.1	< 500

Test method used (TC & FC): Multiple Tube Fermentation Technique, SMEWW 23rd Edition, 2017

Test method used (HPC): Spread Plate Method. 9215 C, SMEWW 23rd Edition, 2017

Room Temperature and %Relative Humidity during analysis: 23°C, 50%

NOTE:

1. This report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results contained in this report relate only to the items received, coded and tested by the laboratory.
3. Measurement uncertainty is available upon request.
4. Statements of conformity (e.g. Pass/Fail) to specifications are made in this report without taking measurement uncertainty into account except when requested by the customer. Where statements of conformity are made in this report, the following decision rules are applied : PASS - Results within limits; FAIL - Results exceed limits

Analyzed by:

WENDY A. TAYSON
Approved Signatory (Micro)

Approved for Release:

ROSELYN C. USERO, RCh, MEE
Manager/Laboratory Head
Approved Signatory (Micro)

Noted by:

JASON JAMES P. LUSABIA, RMT
PRC License No. 72018

Test Report #: MICDW-69063
Laboratory DOH Accreditation # 01
NPPC-ADL LSP 7.8 FO5
Rev. 3/Issue 4
Effectivity Date: 06/15/22